


NOTES:

1. SERVICE LINE PIPING TO BE HELD LOW TO BEYOND PROPOSED CURB WITH A GRADUAL BEND TO WITHIN 12" OF FINISHED GRADE.
2. MAGNETIC TRACER WIRE SHALL BE INSTALLED WITH SERVICE LINE PIPING FROM MAIN LINE TO END OF SERVICE, EITHER AS AN INTEGRAL PART OF PIPE OR SEPARATELY AND IMMEDIATELY ABOVE PIPE.
3. EACH SERVICE LINE SHALL BE PERMANENTLY MARKED WITH A "W" ON THE CURB WHERE THE SERVICE LINE CROSSES THE CURB.
4. CURB STOPS TO REMAIN UNCOVERED UNTIL GPS COORDINATES ARE OBTAINED FOR END OF SERVICE.
5. T-POST, PLASTIC PIPE, OR SOME OTHER SEMI-PERMANENT MARKER, PAINTED BLUE, TO BE PLACED AT END OF SERVICE LINE UNTIL METER AND BOX CAN BE INSTALLED.
6. ALL FITTINGS ARE REQUIRED TO BE "NO LEAD".



**CITY OF TYLER**  
STANDARD DETAIL

**WATER SERVICE  
INSTALLATION**

REVISION DATE:  
MAY 14, 2021